

SURFACE OF COOLING AIR EXHAUST LOUVERS LOUVERS MUST BE, AT LEAST, TWICE SURFACE OF COOLING AIR INTAKE SPACE AROUND FOR MAINTENANCE WORK NOTE: GENERATING SET MUST BE LOCATED WITH, AT LEAST, ONE METER FREE

> Checked Examinated Drawn

Scale

RECOMMENDED INSTALLATION DIMENSIONS

STANDARD GENSET

MEIGHT

EXHAUST GASES: 4765 (M3/H)/5.377 (M3/H) COOLING AIR: 30000 (M3/H) /41.400 (M3/H) COMBUSTION: 2092(M3/H)/1.848(M3/H)

AIR FLOWS:

FUEL CONSUMPTION: 100% LOAD: 94.6 (L/H) / 108.9 (L/H) 75% LOAD: 70.9 (L/H) / 81.7 (L/H) 50% LOAD: NA/NA



400N

DATE

NAME

POWER ENGINEERING

Nº PIGSW530D-560D_B00

Replacing

GSW530D-560D - 1500 RPM